AES-VCM MONG DUONG POWER CO. LTD. MONG DUONG 2 BOT THERMAL POWER PLANT

___***___

ENVIRONMENTAL MONITORING REPORT FOR MONG DUONG 2 BOT THERMAL POWER PLANT

JANUARY - 2016



HA NOI, JANUARY - 2016

AES-VCM MONG DUONG POWER CO. LTD. MONG DUONG 2 BOT THERMAL POWER PLANT

___***___

ENVIRONMENTAL MONITORING REPORT FOR MONG DUONG 2 BOT THERMAL POWER PLANT

JANUARY - 2016

Invested by:
AES-VCM MONG DUONG POWER
PLANT CO., LTD.

Implemented by:
BACH KHOA ENVIRONMENTAL
AMICABLE TECHNOLOGY, JSC.

CÔNG TY
CÔ PHẨN
CÔNG NGHỆ
THÂN THỆN MÔI TRƯNG THẦN
BÁCH KHOA

Ca Văn Son

CONTENTS

TABLES	iii
GENERAL INTRODUCTION ON MONG DUONG 2 BOT THERMAL POWER	
PLANT	.4
CHAPTER I. PLAN OF ENVIRONMENTAL MONITORING PROGRAM IN	
MONG DUONG 2 THERMAL POWER PLANT IN 2016	.7
I.1. The purpose of monirtoring program	.7
I.2. Environmental monitoring parameters and frequency in 2016	.7
I.3. Monitoring positions	.9
I.4. Environmental monitoring method and equipment/instruments	.9
CHAPTER II. RESULTS AND ASSESSMENT1	2
II.1. Water environment	2
II.1.1. Wastewater	2
CHAPTER III. CONCLUSION AND RECOMMENDATION	5
III.1. Conclusion	5
III.2. Recommendation	5
APPENDIX	17
APPENDIX 1. APPLICATION OF QA/QC PROGRAM FOR ENVIRONMETAL	
MONITORING IN MONG DUONG 2 THERMAL POWER PLANT	8
Applying QA / QC program for environmental monitoring Mong Duong 2 phase	
operation in January 2016	8 ا
1. QA/QC in the design of environmental monitoring program	8
2. QA/QC on field monitoring	9
3. Quality assurance and quality control (QA/QC) in laboratory	22
APPENDIX 2. IMAGES OF MONITORING ACTIVITIES ON FIELD	29
APPENDIX 3. MAP OF SAMPLING AREAS	30
APPENDIX 4: THE MONITORING RESULTS	31

FIGURES

Figure 1.1. Mong Duong 2 Thermal Power Plant location	5
Figure 2.1. The chart of Temperature in cooling water	14
Figure 4.1. QA/QC in lab (ISO/IEC 17025:2005)	23
Figure 4.2. Sampling water in Mong Duong 2 thermal power plant	29
Figure 4.3. Map of sampling areas	30

TABLES

Table 1.1. The categories of Mong Duong 2 Thermal Power Plant are used together	er
with Mong Duong 1 Thermal Power Plant in Mong Duong Electricity Power Cent	tre6
Table 1.2. Environmental parameters and frequency	8
Table 1.3. The coordinates of monitoring points in Mong Duong 2 Thermal Power	r
Plant	9
Table 1.4. Method for measurement, sampling and preservation	9
Table 1.5. Analytical methods in the Laboratory	10
Table 2.1. The points of water sampling 11 th environmental monitoring	12
Table 4.1. Summary of quality assurance activities in the design of environmental	<u>[</u>
monitoring program in Mong Duong 2 Power Plant	18
Table 4.2. The current status of quality assurance and quality control activities on	field
(Mong Duong 2 Thermal Power Plant)	19
Table 4.3. The current status of quality assurance and quality control activities at	the
laboratory	23
Table 4.4. On-field blank samples (water)	27
Table 4.5. % RPD of QC duplicate samples (Water)	27

GENERAL INTRODUCTION ON MONG DUONG 2 BOT THERMAL POWER PLANT

Mong Duong 2 Thermal Power Plant is one of two thermal power plant projects. It locates in Mong Duong Electricity Power Centre and has construction site that locates near No. 18A national route. The distance from Mong Duong thermal power plant to Ha Long city is about 50 km and to Cam Pha commune about 18 km in the North East. Mong Duong Electricity Power Centre locates in zone 3, Mong Duong ward, Cam Pha commune, Quang Ninh province. This position lies near Mong Duong estuary and along Luong Gac (Gac Channel). This is an advantage for not only transporting materials by waterway to construction site but also installing cooling water system for two factories. Along South East coast of Electricity Power Centre is range of low mountain. In Luong Gac, there is coal port and chemical store belong Bai Tu Long Coal Company. The plant has total capacity about 1240MW (including two sets of machinery with average capacity is 620MW) with total investment about 2 billion USD. Construction stage was started since September 15th, 2011 and is scheduled supplying commercial electricity for each set of machinery.

- No. 1 set of machinery was operated on March 4th, 2016 with capacity 620MW.
- No.2 set of machinery was operated on April 22nd, 2016 with capacity 620MW. Total capacity is 1240MW.

Area of plant is 81.822 ha. Plant is built in zone 3, Mong Duong ward, Cam Pha commune, Quang Ninh province. Boundary of plant: by the East: beside Binh Minh port; by the South: beside rivulet; by the West: beside Mong Duong 1 thermal power plant; by the North: beside the road which leads to plant and Mon Duong river. The location to build project has many advantages in transferring material by waterway, constructing, investigating, exploiting, and operating plant.

The location of Mong Duong Electricity Power Centre including Mong Duong 2 thermal power plant project and general plan of Centre is shown in **Figure** 1.1




Figure 1.1. Mong Duong 2 Thermal Power Plant location

Mong Duong 2 Thermal Power Plant project is built after Mong Duong Electricity Power Centre completing infrastructures (leveling platform, converting flow of Mong Duong river, completing water collection system, water discharge system to cool, ash dumps...). The works within project include:

- + Infrastructure of thermal power plant: including generator, primary transformer and ancillary works;
 - + The operator, warehouse, workshop;
- + Piping, cooling pump system of general channel from Luong Gac river to Electricity Power Centre.
- + Sewage piping system from plant to Luong Gac canal
- + Channel discharges cooling water into general discharge system of Electricity Power Centre
- + Piping system leads oil from oil receiving point;
- + Slag treating system includes pump station and pump system, which leads slag to general slag, discharged pool of Electricity Power Centre
- + Coal warehouse (about 15 days);

- + Construction treats wastewater;
- + Private road;
- + Fire preventing and fighting system;
- + Temperatureorary and fixed accommodation;
- + The drainage system within plant.
- + Port that receive oil and limestone
- + Slag landfill

The categories used together with Mong Duong 1 Thermal Power Plant are shown in the following table:

Table 1.1. The categories of Mong Duong 2 Thermal Power Plant are used together with Mong Duong 1 Thermal Power Plant in Mong Duong Electricity Power Centre

No.	Categories	Description
1	All area of centre	Mong Duong 2 plant account for 50%
2	Coal receiving region	Using conveyer to transport coal in centre
3	Cooling water supplying channel	This construction is built by EVN. Connection point is pump station in the East of project
4	Cooling water discharging channel	This construction is built by EVN. It locates in the North of project
5	Fresh water supplying system	This construction is built in the North - West by EVN.
6	500 KV connection line	This construction is built by EVN. Mong Duong 2 connection structure inside the distribution station
7	110 KV power supply line for testing in factory	This construction is built by EVN. Mong Duong 2 connected at self-substation to the point inside the
8	Road	At primary road of Mong Duong 2.
9	FO oil and limestone receiving port	Only used by Mong Duong 2. Area is 0.57 ha
Source: AES-VCM Mong Duong Power Co. Ltd., October, 2014		

All general categories of construction are completed and put in use

CHAPTER I. PLAN OF ENVIRONMENTAL MONITORING PROGRAM IN MONG DUONG 2 THERMAL POWER PLANT IN 2016

The environmental monitoring program in January is the 11th monitoring time in operation stage of plant. The main purpose is to show the judge about environment status of plant during operation stage. Environmental monitoring program are performed to make report on periodic environment quality of Mong Duong 2 Thermal Power Plant. This program ensures environmental management object of Mong Duong 2 Thermal Power Plant project to meet the requirements of national environmental protection laws and AES company during operation stage. The detailed objects are shown as following parts:

I.1. The purpose of monirtoring program

The purpose of monitoring program is to evaluate the environmental quality, to examine the pollution level of each environmental component and to collect continuous data to serve environmental management works for Mong Duong 2 Thermal Power Plant and Mong Duong Electricity Power Centre.

In detail:

- ✓ Components, polluted sources, concentration/contents/intensity of pollutants
- ✓ The impact of environmental agents/pollutants
- ✓ Forecasting changes in the levels and effects of these agents
- ✓ Information to managers, namely management board of Mong Duong thermal power plant to take measures in order to mitigate or prevent the harmful effects of environmental pollution caused by the operation of the plant

Besides, this environmental monitoring program is also followed the requirements of approved EIA report of Mong Duong 2 Thermal Power Plant (2007).

I.2. Environmental monitoring parameters and frequency in 2016

All the environmental monitoring parameters are selected typically for each environmental component.

For Mong Duong 2 Thermal Power Plant, monitoring parameters selecting for second monitoring time are strictly complied with EIA report and based on the fact operating stage of the factory.

Main monitoring parameters and frequency are seen in table below:

Environmental Monitoring report of Mong Duong 2 BOT Thermal power plant - January, 2016

Table 1.2. Environmental parameters and frequency

B0		<u> </u>	
Sampling	Quantity	03	01 sample
Tinol	frequency		
	Reference Standard	QCVN40:2011/BTNMT	QCVN40:2011/BTNMT
	Monitoring parameters	Temperature, pH; TSS; EC; NH ₄ ⁺ ; NO ₃ ; DO; BOD ₅ ; Total N&P Heavy metals (As, Cr, Cd, Cu, Pb, Zn, Ni, Hg, Fe, Mn, Se), total oil & grease, Coliform	Temperature; pH; Colour; COD; BOD5; TSS; As,Hg; Pb, Cd, Cr ³⁺ , Cr ⁶⁺ , Cu, Zn, Ni, Mn, Fe, Oil & grease, F', S ²⁻ ; Nutrients (N&P), ; Residual chlorine, amoni and coliform.
ement.	Permit		
Frequency requirement	MONRE EIA		T.
Frequ	ADB EIA		
	Location	CW1, CW2, CW3	From the discharge point into the coolant channels
Tomeof	work	Cooling	Industrial waste water (WW1)
	Item	Water environment	
	٥		

I.3. Monitoring positions

All the environmental monitoring positions are selected by the fact situation of the plant and are followed by the proposed program from EIA report.

The survey was conducted before sampling to examine the monitoring points by GPS-Silva-21802-901, Sweden. The coordinates are listed as in **Table 1.3** follows:

Table 1.3. The coordinates of monitoring points in Mong Duong 2 Thermal Power Plant

Environmental Aspect	No	Location	X	Y
I. WATER	ENVIE	RONMENT		
	CW1	Intake point of cooling water	21°04'32.6"N	107°21'18.5"E
Cooling water	CW2	Discharge point into the cooling water channel	21°04'28.3"N	107°20'57.1"E
	CW3	Discharge point to common Mong Duong Power complex channel	21°04'42.4"N	107°21'03.1"E
Industrial waste water	ww1	Discharge point into the Cooling water channel	21°04'31.1"N	107°21'04.4"E

I.4. Environmental monitoring method and equipment/instruments

Main environmental monitoring methods are:

- ✓ Surveying, collecting data, sampling, on-field measurement;
- ✓ Sampling, preservation and measurement on-field and laboratory in compliance with current Vietnamese standards, circulars and regulations;
- ✓ Data processing and evaluation, statistical method in comparison to QCVN/TCVN

Methods for measurements, sampling and preservation; equipment/instruments are as in Table 1.4 and Table 1.5

Table 1.4. Method for measurement, sampling and preservation

No	Environmental	Name/ number of	Equipment / LOD
	components	sampling and	

		measurement methods	
TCVN 6663-1:2011, TCVN 5999:1995, TCVN 666		CVN 5999:1995, TCVN 6663-	
WASTEWATER 3:2008			
1	Temperature	TCVN 4557:1988	From 0 - 80°C
2	pH	TCVN 6492:2011	From 0 – 14

Table 1.5. Analytical methods in the Laboratory

No	Environmental components	Name/ number of	MDL/LOD	
NO	Environmental components	analytical methods	MDL/LOD	
WA	STEWATER		···	
1	Colour	TCVN 6185: 2008	5 Pt -Co	
2	BOD ₅ (20°C)	TCVN 6001-1:2008	2 mg/L	
3	COD	SMEWW 5220 C:2012	2 mg/L	
4	Total suspended solid (TSS)	TCVN 6625 : 2000	2 mg/L	
5	TDS	SOP-TDS	0 - 1.999 mg/L	
5	Asen (As)	EPA 200.8	1.26 μg/L	
6	Mercury (Hg)	EPA 200.8	0.72 μg/L	
7	Lead (Pb)	EPA 200.8	0.72 μg/L	
0	C-1:: (C1)	EPA 200.8	0.6 μg/L	
8	Cadimi (Cd)	TCVN 6193:1996	0.006 mg/L	
9	Chrome VI (Cr ⁶⁺)	TCVN 7939:2008	2.3 μg/L	
10	Chrome III (Cr ³⁺)	TCVN 6665:2000	2.3 μg/L	
11	(O)	EPA 200.8	9.15 μg/L	
11	Copper (Cu)	TCVN 6193:1996	0.013 mg/L	
10	7: (7m)	EPA 200.8	1.59 μg/L	
12	Zinc (Zn)	TCVN 6193:1996	0.014 mg/L	
12	Nilrol (Nii)	EPA 200.8	3.21 μg/L	
13	Nikel (Ni)	TCVN 6193:1996	0.022 mg/L	
14	Mangan (Mn)	EPA 200.8	3.87 μg/L	
15	Iron (Fe)	EPA 200.8	5.31 μg/L	
16	Mineral Oil	EPA 1664	0.3mg/L	
17	Florua (F-)	TCVN 6494-1:2011	>0,1mg/L	
10	Sulfide (calculated by H ₂ S)	SMEWW 4500-S ² -	0.03 mg/L	
18	Surfice (calculated by Π_2S)	D:2012	0.05 mg/L	
19	Total Nitrogen	TCVN 6638:2000	3 mg/L	

20	Total phosphorus	TCVN 6202: 2008	0.017 mg/L,
20		1CVN 6202: 2008	0.05 – 4mg/l
21	Residual Chlorine	TCVN 6225 – 3:2011	0.17 mg/L
22	Amoni (calculated by N)	SMEWW 4500-NH ₄ ⁺ -F	0.23 mg/L
22		TCVN 6179-1:1996	0.3 mg/L
25	Coliform	TCVN 6187-2:1996	3 MPN/100 mL
18	Coliform	TCVN 6187-2:1996	3MPN/100mL

Notes:

- TCVN: Viet Nam standards
- SOP-CO: Standard Operating Procedure for on-field sampling of CO
- MASA: Methods of Air Sampling and Analysis
- AS/NZS: Australian/New Zealands Standards
- EPA: Environment Protection Agency
- SMEWW: Standard Method for The Examination of Water and Waste Water
- SVOC: Semivolatile Organic Compounds
- VOC: Volatile organic compound
- TPH: Total petroleum hydrocarbon

CHAPTER II. RESULTS AND ASSESSMENT

The 11th Environmental monitoring time in operation time of Mong Duong 2 plant was implemented in the period from 21/01/2016 at 03 cooling water samples and 01 industrial wastewater sample. The monitoring results are shown in the following sections.

II.1. Water environment

Water samples are monitored including wastewater, surface water, coastal water, detailed water sampling locations as **table 2.5** below:

Table 2.1. The points of water sampling 11th environmental monitoring

Water environment	Samples	Points	Coord	linates
Industrial waste water	WW1	From discharge point to cooling water chanel	21°04'31.1"N	107°21'04.4"E
	CW1	Intake point of cooling water	21°04'32.6"N	107°21'18.5"E
Cooling water	CW2	Discharge point into the cooling water canal	21°04'28.3"N	107°20'57.1"E
	CW3	Discharge point to common Mong Duong Power complex canal	21°04'42.4"N	107°21'03.1"E

Evaluating the results of environmental monitoring of water as the following sections:

II.1.1. Wastewater

Wastewater of the plant in the 11th monitoring program includes 01 industrial wastewater sample and 03 samples of cooling water.

a. Industrial wastewater

The influent industrial wastewater includes irregular wastewater, regular wastewater and oil contaminated wastewater. The capacity of industrial wastewater treatment system is 110 m³/h. The sample WW was taken at the discharge point into the cooling water channel. At the monitoring time, the industrial wastewater treatment system operates normally. The detailed monitoring points are below:

WW: From discharge point to cooling water chanel

The result shows that all the parameters of industrial wastewater are lower than QCVN 40:2011/BTNMT column B. Copare with the **TCW-AES-TKV**: The standard of Mong Duong 2 BOT thermal power plant about permitted limit of industrial wastewater,

all parameter meet allowed standard. This demonstrates that the industrial wastewater treatment system works extremely well.

b. Cooling water

In order to estimate the quality of cooling water supply for plant and also discharging cooling wastewater, cooling water was taken at 03 positions at 03 intake points of cooling water, discharge point into the cooling water channel and discharge point to common Mong Duong power complex channel. The detailed positions:

- CW1: Intake point of cooling water
- CW2: Discharge point into the cooling water channel
- CW3: Discharge point to common Mong Duong Power complex channel

At the monitoring time, the plant operates in normal condition. Capacity of cooling water is about 4,000,000 m³/ day.night. According to the design of cooling water system as well as the characteristics of the cooling water, two parameters that need to be tightly controlled are Temperature and residual chlorine. In addition, the quality of the cooling wastewater is compared with QCVN 40:2011/BTNMT- National technical regulation on industrial wastewater. Due to the characteristics of the cooling water does not contain many polluted factors so the monitoring results therefore also reflect the fact that the monitoring parameters are achieved strictly allowed standard of the plant -GVC-AES-TKV- Standards of BOT Mong Duong 2 thermal power plant of the permitted limit value of cooling water. Monitoring the temperature of the coolants after discharging into the environment is also quite important to ensure that the cooling water does not affect the aquatic environment. Fluctuated temperature in cooling water is as shown below:




Figure 2.1. The chart of Temperature in cooling water

The temperature dropped off from CW3, CW2 to CW1, the temperature in cooling water into the environment has reduced to the air's temperatures roughly, and tend to cool down slowly in the direction of flow.

CHAPTER III. CONCLUSION AND RECOMMENDATION

III.1. Conclusion

The 11th Environmental monitoring program in operation stage of Mong Duong 2 thermal power plant was conducted in January, 2016, the sampling locations were approved according to plan, the environmental monitoring factors includes: waste water, cooling water. Based on the results of environmental monitoring, the assessment of environmental quality in the area of the plant in operation stage as follows

Wastewater:

Wastewater of the plant in the 11th monitoring time includes 01 industrial wastewater sample. In which, parameters of industrial wastewater are smaller than allowed standard (QCVN 40:2011/BTNMT), and TCW-AES-TKV: The standard of Mong Duong 2 BOT thermal power plant about permitted limit of industrial wastewater.

Cooling water

Monitoring Results of the cooling water samples showed that all the monitoring parameters are allowed to the standards of QCVN 40: 2011 / BTNMT and GVC-standard AES-TKV- Standards of BOT Mong Duong 2 Thermal power plants of the permitted limit value of cooling water.

III.2. Recommendation

Based on the monitoring results of the 11th monitoring time in operation stage in Duong Duong 2 Thermal Power plant, the monitoring team and implementing units may give some recommendations to the management board of Mong Duong 2 thermal plants and the contractor at the plant as follows:

Continue implementation of environmental monitoring activities periodically with the noise component, ambient air, wastewater, surface water, ecological environment according to plan, the roadmap setting out in the region during the operation stage of Mong Duong 2 thermal power plant. This is in order to detect early signs of environmental pollution due to the impact of the plant through each stage or other events affecting the region.

Continue and expand the assessment of the impact of plant's operations to the surrounding residential area. Especially we should focus on evaluating expansion and more detailed assessment of environmental ambient air, surface water area. Study and estimate the impact of 2 plants to people's living. Beside the influence of environment, it is need to assess the social impact on population in Mong Duong 2 thermal power plant area.

Providing updated information on the situation of the environment for the local area and building contractors to have plans for dealing with pollution as well as minimize the polluting activity to the regional environment.

During construction works or auxiliary expansion of mills', contractors should strictly implement measures to reduce air pollution and surface water, coastal, especial attention to the area has signs of contamination.

Disseminating environmental information is to raise people's awareness in the community and region.

APPENDIX 1. APPLICATION OF QA/QC IN MONITORING PROGRAM

APPENDIX 2. IMAGES OF MONITORING ACTIVITIES ON FIELD

APPENDIX 3. MAP OF SAMPLING AREAS

APPENDIX 4. THE MONITORING RESULTS

APPENDIX 1. APPLICATION OF QA/QC PROGRAM FOR ENVIRONMETAL MONITORING IN MONG DUONG 2 THERMAL POWER PLANT

Applying QA / QC program for environmental monitoring Mong Duong 2 phase operation in January 2016

1. QA/QC in the design of environmental monitoring program

Activities to ensure quality in the design of environmental monitoring program for Mong Duong 2 Thermal Power Plant are summarized in **Table 4.1** follows (compare current status with the requirements of Circular 21/2012/TT-BTNMT on 19/12/2012, Ministry of Natural Resources and Environment guiding the quality assurance and quality control in environmental monitoring).

Table 4.1. Summary of quality assurance activities in the design of environmental monitoring program in Mong Duong 2 Power Plant

		Current status in	
No	Activities	comparison to the	Note
No.	Acuvines	requirements of	Note
	:	Circular 21	
1	Determine the objectives	+	
	of monitoring program		
2	Design the environmental	+	Monitoring in cooling water,
	monitoring program		waste water in the plant
2.1.	Compliance with	+	
	environmental protection		
	programs and national		
	strategies		
2.2.	To comply with the	+	QCVN 40:2011/BTNMT of
	technical guidance,		Ministry of Environment and
	procedures and		Resources: National
	regulations for each		Technical Regulation on
	environmental component		industrial wastewater.
			Circular No. 29/2011/TT-
			BTNMT of Ministry of
			Natural Resources and
			Environment: Technical
			Regulation on environmental
			monitoring procedures of

		surface water	
2.3.	Follow all steps in design environmental monitoring program	+	
Note:	(+) full	(-) not enough	

2. QA/QC on field monitoring

The activities on field can be classified as follows:

- ✓ QA/QC in direct measurement on field (this activity can be operated independently out of other activities);
- ✓ QA/QC in sampling, sample pretreatment, samples preservation;

In this environmental monitoring program for Mong Duong 2 Power Plant, QC samples were carried out include: On field blank sample (code: QCHT). This is defined as the small sample of handled clean material, which is stored, transported and analyzed in laboratory similar to real samples. These QC samples are used to control contamination in the sampling process.


On-field blanks for wastewater are COD and TSS

✓ QA/QC in transporting samples to the laboratory

QC sample was choosen transportation blank sample (code: QCVC). QCVC is a small sample of the clean material transporting and researching with true samples in the same environment, the preservation and analysis of laboratory parameters as true sample. This QC sample types are used to control contamination during transporting samples.

Transportation blanks sample for wastewater: COD and TSS

QC sample at the laboratory (code: QCPTN) is replicate analyzed for the same above parameters.



Activities to quality assurance in the field of monitoring are summarized in **Table 4.2** follows:

Table 4.2. The current status of quality assurance and quality control activities on field (Mong Duong 2 Thermal Power Plant)

No.	Activities	Current status in comparison to the requirements of Circular 21	Notes
1	Environmental Monitoring on field	+	Followed the plan
1.1.	Determination of environmental parameters	+	Represent for each environmental component, based on proposed report of EIA
1.2.	Analytical method	+	Current Vietnamese standards (TCVN)
1.3.	On-field environmental facilities and equipment	+	Periodically maintenance and calibration
1.4.	Chemicals, standards	+	Prepare before going to the field
1.5.	Personnel	+	Assign members of performing each items
1.6.	Data processing and reporting	+	
1.7.	Quality control	-	Applied QC samples for 02 parameters in wastewater, not for all parameters.
2.	Sampling, samples pre- treatment and preservation on field	+	Followed current Vietnamese standards (TCVN)
2.1.	Quality assurance	+	
2.1.1.	Determination of sampling site	+	Representative for the area, followed the surveyed results

No.	Activities	Current status in comparison to the requirements of Circular 21	Notes
2.1.2.	Assurance of monitoring parameters	+	Followed the plan
2.1.3.	Assurance of sampling time and frequency	- -	Followed the plan, some changes in accordance to train schedule
2.1.4.	Sampling methods, samples pre- treatment and preservation	+	Followed current Vietnamese standards (TCVN)
2.1.5.	Equipment and instruments	+	Periodical maintenance and calibration
2.1.6.	Personnel	+	Group work
2.1.7.	Sample containers	+	Cleaned and sterilized
2.1.8.	Chemicals	+	
2.1.9.	On-field sampling minutes	+	
2.2.	Quality control	<u>-</u>	Applied QC samples for 02 parameters 02 parameters in wastewater samples, not for all parameters
3.	Sample transportation to laboratory	+	
3.1.	Quality assurance	+	
3.1.1.	Sample transportation	+	
3.1.2.	Sample delivery	+	Using delivery minute




Figure 4.1. QA/QC in lab (ISO/IEC 17025:2005)

Table 4.3. The current status of quality assurance and quality control activities at the laboratory

/היים יודעד מדע

No	Activities	Current statusin comparison to the requirementsof Circular21	Notes
4.	QA/QC at the laboratory	+	According to the laboratory regulations (ISO/IEC 17025 VILAS No 406 of R & D laboratory — Institute for Environmental Science and

25

No	Activities	Current statusin comparison to the requirementsof Circular21	Notes	
			Technology)	
4.1.	Management requirement	+	-as above-	
4.1.1.	Determine the laboratory organization, appoint the duty and responsibility for each staff	+	-as above-	
4.1.2.	Document system	+	-as above-	
4.1.3.	Internal evaluation	+	-as above-	
4.1.4.	Periodical review the quality management system and laboratory operation to ensure the effectiveness and continuous	nd laboratory		
4.2.	Technical requirement	+	-as above-	
4.2.1.	Quality assurance (analytical method, method selection, and method approval)	+	-as above-	
	Facilities and equipment (calibration, labelling, maintenance)	+	-as above-	
	Inter-laboratory comparison	+	-as above-	
	Environmental condition	+	-as above-	
	Sample management	+	-as above-	
	Data quality assurance	+	-as above-	
4.2.2.	Quality control	+	-as above-	
	Using QC samples	+	-as above-	
	Develop the QC accepted criteria	+	-as above-	
5.	QA/QC in data processing and reporting	+	-as above-	
5.1.	Environmental Monitoring data processing and management	+	Using software issued by Ministry of Natural resources and environment	

ř


No	Activities	Current statusin comparison to the requirementsof Circular21	Notes
5.1.1.	Documents related to monitoring process needed to update	+	According to the laboratory regulations (ISO/IEC 17025 VILAS No 406 of R & D laboratory — Institute for Environmental Science and Technology)
5.1.2.	Store all document related to monitoring process	+	Followed the form issued by Ministry of Natural Resources and Environment
5.1.3.	Check, calculate and process all data from the field and/or laboratory	+	According to the laboratory regulations (ISO/IEC 17025 VILAS No 406 of R & D laboratory — Institute for Environmental Science and Technology)
5.2.	Reporting	+	-as above-
5.2.1.	Phase report needed to ensure the accuracy and honest	+	-as above-
5.2.2.	Review the reports	+	-as above-
5.2.3.	Report submitting	+	Submit to client and save the data

3.2. (QC) in Lab

QC samples include:

- QC sample for equipment
- QC sample for methods: Selected the duplicates at the Lab with the COD and TSS in water.

QC sample types:



In this environmental monitoring program for Mong Duong 2 Thermal Power Plant in January 2016, QC samples (blanks and duplicates) were carried out at all sampling sites with some parameters of wastewater in parallel with true samples.

QC sample on field is included: On-fields blank sample (code: QCHT), transportation blank sample (code: QCVC), applied for 02 parameters of water (COD and TSS). The analytical requirement for blank is less than MDL (method detection limit) or LOD (Limit of detection). In case the result is higher than these levels, it is needed to analyze again in order to remove the error cause.

QC sample at the laboratory (code: QCPTN) is replicately analyzed for the same above parameters.

Results were calculated, compared, followed the formula:

RPD: Relative Percent Difference

$$RPD = \frac{|LD1 - LD2|}{[(LD1 + LD2)/2]} \times 100 \,(\%)$$

In which:

- RPD: Relative Percent Difference
- LD1: first analytical result
- LD2: second analytical result (duplicate)

The requirement of dispersion level between duplicate and true samples is not over $\pm 20\%$ (expected quality target of the laboratory).

3.3. QC sample analytical results

3.3.1. On-field blank sample analytical results

The 11th environmental monitoring time conducted with 02 QC samples: On-field blank sample, transportation blank sample of 02 parameters: COD and TSS

Table 4.4.	On-field	blank	samples	(water)
------------	----------	-------	---------	---------

Type of	Codo	COD	(mg/l)	TSS (mg/l)		
sample	Code	% value ≤2	% value ≥2	% value ≤2	% value ≥2	
QCHT: on-	CW1	100	0	100	0	
field blank samples	WW1	100	0	100	0	

3.3.2. Duplicate sample analytical results

Selected QC samples were duplicates in Lab (QCPTN) with parameters of COD and TSS in water. In detail:

Table 4.5. % RPD of QC duplicate samples (Water)

No.	Code	% RPD		
	·	COD	TSS	
1.	CW1	4.082	6.185	
2.	WW1	9.221	3.046	

QA/QC activity was conducted fully as design in monitoring program; therefore, the above results shown rather good with the expected quality target of the laboratory within RPD +20% (meet the requirements of the Lab).

3.3.3. Evaluation on completed monitoring data

Completed monitoring data is evaluated by percent of full data in comparison to the expected data in the begin of plan.

Formula using for percent of completed data as bellows:

$$C = \frac{V}{T} \times 100(\%)$$

In which:

- C: % of completed data
- V: number of acceptable samples
- T: total samples in beginning plan

Here $C \ge 95\%$ is acceptable.

In this monitoring program (January 2016) for Mong Duong 2 Thermal Power Plant, there were 01 wastewater samples, 03 cooling water samples.

Therefore:

$$C = \frac{V}{T} \times 100(\%) = \frac{4}{4} \times 100(\%) = 100 \%$$

C = 100% is ensured the completed data in this monitoring program of January 2016.

APPENDIX 2. IMAGES OF MONITORING ACTIVITIES ON FIELD




Figure 4.2. Sampling water in Mong Duong 2 thermal power plant

20

APPENDIX 3. MAP OF SAMPLING AREAS



Figure 4.3. Map of sampling areas

APPENDIX 4: THE MONITORING RESULTS



TRƯỜNG ĐẠI HỌC BÁCH KHOA HÀ NỘI VIỆN KHOA HỌC VÀ CÔNG NGHỆ MÔI TRƯỜNG

Tầng 3, nhà C10 - Trường Đại học Bách Khoa Hà Nội, số 1 Đại Cồ Việt, Hai Bà Trưng, Hà Nội ĐT: (04).38681686 Fax: (04).38693551



MÔI TRI

A) HOC E

Số: 01/04/TTQT-2016

KÉT QUẢ QUAN TRẮC MÔI TRƯỜNG

Địa điểm lấy mẫu: Nhà máy nhiệt điện Mông Dương 2

Dia chỉ : Phường Mông Dương – TP. Cẩm Phả – tỉnh Quảng Ninh

Ngày quan trắc : 21/01/2016 Loại mẫu : Nước làm mát

Loại mẫu : Nước làm Số lượng mẫu : 03 mẫu

TETE.	Thêma số	Châng số Dơn Thương pháp		Kết quả	Kết quả		N 40: ΓΝΜΤ	
TT	Thông số	vį	phân tích	CW1	CW2	CW3	C (Cột B)	Cmax
1.	Nhiệt độ	°C	SMEWW 2550B:2012	21,4	25,6	25,5	40	40
2.	рН	-	TCVN 6492:2011	8,0	8,4	8,0	5,5-9,0	5,5-9,0
3.	Màu	Pt/Co	TCVN 6185:2008	<5	<5	<5	150	150
4.	COD	mg/l	SMEWW 5220C:2012	15	19	15	150	135
5.	BOD ₅	mg/l	TCVN 6001- 1:2008	5	7	7	50	45
6.	TSS	mg/l	TCVN 6625:2000	5	11	9	100	90
7.	TDS	mg/l	SOP-TDS	23.300	23.700	23.500	-	- 1/3
8.	Asen (As)	mg/l	EPA 200.8	0,0209	0,0201	0,0196	0,1	0,09
9.	Thủy ngân (Hg)	mg/l	EPA 200.8	0,0043	0,0048	0,0049	0,01	0,009
10.	Chì (Pb)	mg/l	EPA 200.8	0,0001	0,00004	0,00004	0,5	0,45
11.	Cadimi (Cd)	mg/l	EPA 200.8	0,0007	0,0006	0,0006	0,1	0,09
12.	Crom III (Cr ³⁺)	mg/l	SMEWW 3113B:2005	0,036	0,033	0,035	1	0,9
13.	Crom VI (Cr ⁶⁺)	mg/l	TCVN 6658:2000	0,006	0,006	0,007	0,1	0,09
14.	Đồng (Cu)	mg/l	EPA 200.8	0,125	0,145	0,125	2	1,8
15.	Kêm (Zn)	mg/l	EPA 200.8	0,051	0,033	0,041	3	2,7
16.	Niken (Ni)	mg/l	EPA 200.8	0,0010	0,0018	0,0010	0,5	0,45
17.	Mangan (Mn)	mg/l	EPA 200.8	0,012	0,006	0,008	1	0,9
18.	Sắt (Fe)	mg/l	EPA 200.8	0,773	0,782	0,794	5	4,5
19.	Dầu mỡ khoáng	mg/l	EPA-1664	<0,2	<0,2	<0,2	10	9
20.	Florua (F ⁻)	mg/l	TCVN 6494- 1:2011	0,132	0,142	0,132	10	9
21.	Sunfua (tính theo H ₂ S)	mg/l	SMEWW 4500 S ²⁻ .D:2012	<0,03	<0,03	<0,03	0,5	0,45
22.	Tổng N	mg/l	TCVN 6638:2000,	0,73	0,65	0,72	40	36
23.	Tổng P	mg/l	TCVN 6202:2008	0,036	0,028	0,034	6	5,4
25.		T	TCVN 6225-	-0.2	~n ?	0.3	2	1.8

ТТ	Thông số	Đơn	01		Kết quả			QCVN 40: 2011/BTNMT	
11	I nong so	vị phân tích	CW1	CW2	CW3	C (Cột B)	Cmax		
25.	Amoni (tính theo N)	mg/l	SMEWW 4500 NH ₃ .F:2012	0,27	0,17	0,22	10	9	
26.	Coliform		TCVN 6187- 2:1996	1.600	1.500	1.100	5.000	5.000	

Ghi chú:

Phiếu kết quả chỉ có giá trị đối với mẫu tại thời điểm quan trắc. Ký hiệu (-): Không quy định.

QCVN 40:2011/BTNMT- Quy chuẩn kỹ thuật quốc gia về nước thải công nghiệp; cột B quy định giá trị C của các thông số ô nhiễm trong nước thải công nghiệp khi xả vào nguồn nước không dùng cho mục đích cấp nước sinh hoạt;

C_{max} là giá trị tối đa cho phép của thông số ô nhiễm trong nước thải công nghiệp khi thải xả vào nguồn

tiếp nhận nước thải (mg/l). C_{max} được tính như sau:

 $C_{max} = C \times K_q \times K_f = C \times 1 \times 0,9 = 0,9 \times C$

Trong đó:

+ C: Giá trị nồng độ của thông số ô nhiễm quy định trong QCVN 40:2011/BTNMT;

+ K_q : Hệ số theo lưu lượng/ dung tích nguồn tiếp nhận nước thải, vùng nước biển ven bờ dùng cho mục đích bảo vệ thủy sinh, thể thao hoặc giải trí dưới nước áp dụng $K_q = I$

+ K_f : Hệ số theo lưu lượng nguồn thải F > 5.000 m3/ngày đêm nên áp dụng $K_f = 0.9$

Vi trí lấy mâu:

CW1:Đầu vào nước làm mát

CW2:Điểm xả ra kênh nước làm mát

CW3:Điểm xả vào kênh chung của nhiệt điện Mông Dương

Toa đô

21°04'15.6"N 107°20'02,4"E 21°04'28,3"N 107°20'57,1"E

21°04'42,4"N 107°21'03,1"E



TS. Nguyễn Thị Thu Hiền

Hà Nội, ngày 15 tháng 02 năm 2016 & KHỆ Viên Khoa học và Công nghệ Môi trường

VIỆN TRƯỞNG

PGS.TS. Nghiêm Trung Dũng



TRƯỜNG ĐẠI HỌC BÁCH KHOA HÀ NỘI VIỆN KHOA HỌC VÀ CÔNG NGHỆ MÔI TRƯỜNG

Tầng 3, nhà C10 - Trường Đại học Bách Khoa Hà Nội, số 1 Đại Cồ Việt, Hai Bà Trưng, Hà Nội ĐT: (04).38681686 Fax: (04).38693551



Số: 02/04/TTQT-2016

TDS

Asen (As)

Chì (Pb)

Cadimi (Cd)

Crom III (Cr³⁺)

Crom VI (Cr⁶⁺)

Đồng (Cu)

Kem (Zn)

Sắt (Fe)

Niken (Ni)

Florua (F⁻)

theo H₂S)

Tổng N

Tổng P

24. Clo du

Sunfua (tính

Mangan (Mn)

Dầu mỡ khoáng

Thủy ngân (Hg)

7.

8.

10.

11.

12.

13.

14.

15.

16.

17.

18.

19.

20.

21.

22.

23.

KÉT QUẢ QUAN TRẮC MÔI TRƯỜNG

Địa điểm lấy mẫu: Nhà máy nhiệt điện Mông Dương 2

Dia chỉ : Phường Mông Dương – TP. Cẩm Phả – tỉnh Quảng Ninh

Ngày quan trắc : 21/01/2016

Loai mẫu : Nước thải công nghiệp

Số lương mẫu : 01 mẫu

TOTO	Thâng gấ	số Đơn vị	Phương pháp phân	Kết quả	QCVN 40: 2011/BTNMT	
TT	Thông số	Don vi	tích	WW1	C (Cột B)	Cmax
1.	Nhiệt độ	°C	SMEWW 2550B:2012	22,1	40	40
2.	pН	-	TCVN 6492:2011	8,7	5,5-9,0	5,5-9,0
3.	Màu	Pt/Co	TCVN 6185:2008	6	150	150
4.	COD	mg/l	SMEWW 5220C:2012	25	150	135
5.	BOD ₅	mg/l	TCVN 6001-1:2008	11	50	45
6.	TSS	mg/l	TCVN 6625:2000	10	100	90

SOP-TDS

EPA 200.8

EPA 200.8

EPA 200.8

EPA 200.8

SMEWW

3113B:2005

EPA 200.8

EPA 200.8

EPA 200.8

EPA 200.8

EPA 200.8

EPA-1664

.D:2012

TCVN 6494-1:2011

SMEWW 4500 S²-

TCVN 6638:2000

TCVN 6202:2008

TCVN 6225-3:2011

TCVN 6658:2000

mg/l

mg/1

mg/l

mg/l

mg/l

mg/l

mg/l

mg/l

231

0,0009

<0,0001

0,0002

< 0.0001

0,006

0,001

0,033

0,016

0,0003

0,035

0,031

< 0.2

0,114

< 0.03

4,2

0,100

1,10



0,09

0,009

0,45

0,09

0,9

0.09

1,8

2,7

0,45

0,9

4,5

9

9

0,45

36

5,4

1,8

0,1

0,01

0,5

0,1

1

0,1

2

3

0,5

1

5

10

10

0,5

40

6

2

TT	Thông số	Đơn vị	Phương pháp phân tích	Kết quả WW1	QCVN 40: 2011/BTNMT	
					C (Cột B)	Cmax
25.	Amoni (tính theo N)		SMEWW 4500 NH ₃ .F:2012	3,88	10	9
26.		MPN/100 ml	TCVN 6187-2:1996	2.400	5.000	5.000

Ghi chú:

Phiếu kết quả chỉ có giá trị đối với mẫu tại thời điểm quan trắc. Ký hiệu (-): Không quy định.

QCVN 40:2011/BTNMT- Quy chuẩn kỹ thuật quốc gia về nước thải công nghiệp; cột B quy định giá trị C của các thông số ô nhiễm trong nước thải công nghiệp khi xả vào nguồn nước không dùng cho mục đích cấp nước sinh hoạt;

C_{max} là giá trị tối đa cho phép của thông số ô nhiễm trong nước thải công nghiệp khi thải xả vào nguồn

tiếp nhận nước thải (mg/l). C_{max} được tính như sau:

$$C_{max} = C \times K_q \times K_f = C \times 1.0 \times 0.9 = 0.9 \times C$$

Trong đó:

+ C: Giá trị nồng độ của thông số ô nhiễm quy định trong QCVN 40:2011/BTNMT;

+ Kq: Hệ số theo lưu lượng/ dung tích nguồn tiếp nhận nước thải $K_q=1,0$

+ K_f : Hệ số theo lưu lượng nguồn thải K_f =0,9

Vị trí lấy mẫu:

WW1: Từ điểm xả thải vào kênh nước làm mát

Tọa độ

21°04'31,1"N 107°21'04,4"E

ong the nghien R& D m /ILAS 406

TS. Nguyễn Thị Thu Hiền

Hà Nội, ngày 15 tháng 02 năm 2016 Viện Khoa học và Công nghệ Môi trường VIÊN

> KHOA HOC YA (MÔI TRƯ

> > HOC BA

VIỆN TRƯỞNG PGS.TS. Nghiêm Trung Dũng